



REFER TO M4.1 FOR
DRAWING OF THIS AREA

CORPORATE ROUTE AND ELEVATION
ON THIS LOCATION

12x10 UP THROUGH SECOND FLOOR
CHASE TO EF-7 ON ROOF.
PUSH BUTTON FOR HOOD FIRE
1.5 RADIUS ELBOW
ANSUL FIRE SUPPRESSION SYSTEM FOR KH-1

REFER TO DEMOLITION ALTERNATE
TO CAP AND INSULATE DUCTWORK
PENETRATING PERIMETER OF SPACE.
IF ALTERNATE IS ACCEPTED
EVEN IF ALTERNATE IS ACCEPTED
KITCHEN HOOD SUPPRESSION SYSTEM
AND FANS TO BE FURNISHED AND
INSTALLER AS PART OF FINISHED
AND STORED IN UNOCCUPIED SPACE
FOR FUTURE INSTALLATION.

REINFORCE GULCH WITH DUCT TYPICAL
BASED ON DRAWING 11

- DEMOLITION / RELOCATION NOTES:
- 1 REMOVE EXISTING EXHAUST GRILLE AND DUCTWORK
BACK TO EXHAUST FAN CAP DUCTWORK AT EXHAUST FAN
 - 2 RELOCATE EXISTING MODULE DIFFUSERS AS INDICATED
PROVIDE NEW DUCTWORK AS REQUIRED.
 - 3 RELOCATE EXISTING MODULE DIFFUSERS AS REQUIRED
FOR NEW CEILING SYSTEM.
 - 4 RELOCATE EXISTING TRANSFER DUCT AS INDICATED.
 - 5 RELOCATE EXISTING HEATING SYSTEM AND GRILLES AS
INDICATED. PROVIDE NEW DUCTWORK AS REQUIRED.
 - 6 EXISTING THERMOSTAT TO REMAIN.

MECHANICAL
FIRST FLOOR PLAN
1/8" = 1'-0"